

Oscillogram No.: HPL3-34424 OCV = 260 V
Date of Test: 9/30/2020 Time of Test: 10:04:07 AM

AVAILABLE CIRCUIT CHARACTERISTICS:

Osc. No: 34341 Calibration Date: 09/28/20
OCV = 354 V Rms Sym Current = 13.34 kA
Power Factor = 29%



High Power Laboratory, HPL3 Facility
Cedar Rapids, Iowa, USA

Project No.: 6000001332 TestFlow No.: UTK

Test Device: ARC FLASH

Sample No.: 85

ANALYSIS RESULTS TABLE

Closing Angle	234 Deg
Closing time (V0)+	10.83 m Sec
Peak Current (Ip)	-25.38 k Amperes
Time to Ip	4.877 m Sec.
I ² t	2.766 M Amp ² sec
I Duration	8.282 m Sec.


Performance Observations

Was the Breaker Tripped after the test?	NA
Could the Breaker be Reset?	NA
Did it have continuity in all poles?	NA
Was the Enclosure Fuse Opened?	NA


Comment Section

9.79 kA
-
-

Analysis results are based on this data



TOTAL VIEW



INSTRUMENTATION DATA

Data Recording System: HBM GENST C/N 063-173

VOLTAGE: 100X Scope Probe, C/N 131-555, 1%

PLOT FILE HPL3 CR_1_M

VOLTAGE: 100X Scope Probe, C/N 131-604, 1%

CURRENT: ROGOWSKI COIL, C/N 045-445

NOTE: Channel offset removed for analysis.
but not for display.

OSC. NO.: HPL3-34424

