

Oscillogram No.: HPL3-27883 OCV = 241 V
Date of Test: 6/9/2020 Time of Test: 9:32:55 AM

AVAILABLE CIRCUIT CHARACTERISTICS:
Osc. No: 30017 Calibration Date: 5/05/2020
OCV = 240 V Rms Sym Current = 10.01 kA
Power Factor = 47%



High Power Laboratory, HPL3 Facility
Cedar Rapids, Iowa, USA

Project No.: 6000001332 TestFlow No.: UTK
Test Device: ARC FLASH
Sample No.: 9

ANALYSIS RESULTS TABLE

Closing Angle	173 Deg
Closing time (V0)+	8.003 m Sec
Peak Current (Ip)	15.63 k Amperes
Time to Ip	15.30 m Sec.
I ² t	2.698 M Amp^2sec
I Duration	39.71 m Sec.


Performance Observations

Was the Breaker Tripped after the test?	NA
Could the Breaker be Reset?	NA
Did it have continuity in all poles?	NA
Was the Enclosure Fuse Opened?	NA


Comment Section

-	
-	
-	

Analysis results are based on this data



TOTAL VIEW



INSTRUMENTATION DATA

Data Recording System: HBM GEN3T C/N 063-173
VOLTAGE: 100X Scope Probe, C/N 131-555, 1%
VOLTAGE: 100X Scope Probe, C/N 131-604, 1%
CURRENT: ROGOWSKI COIL, C/N 045-445

NOTE: Channel offset removed for analysis.
but not for display.

OSC. NO.: HPL3-27883

